



Product Service

CERTIFICATE

No. Z2 110094 0001 Rev. 01

Holder of Certificate: **SOLVIS d.o.o.**
Vesne Parun 15
42000 Varazdin
CROATIA

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262013601-01

Valid until: 2025-11-16

Date, 2021-03-01

(Zhulin Zhang)

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFIKAT ◆ CERTIFICATE

CERTIFICATE

No. Z2 110094 0001 Rev. 01

Model(s):

SV72-xxx E, xxx=330-400 in step of 5,
 SV60-xxx E, xxx=275-335 in step of 5,
 SV54-xxx E, xxx=250-270 in step of 5,
 SV48-xxx E, xxx=220-245 in step of 5,
 SV72(5)-xxx E, xxx=195-200 in step of 5,
 SV36(5)-xxx E, xxx=95-100 in step of 5,
 SV144-xxx E HC, xxx=365-415 in step of 5,
 SV120-xxx E HC, xxx=305-345 in step of 5,
 SV144-xxx E HC9B, xxx=420-450 in step of 5,
 SV120-xxx E HC9B, xxx=350 to 375 in step of 5
 xxx is standing for rated output power at STC

Parameters:

Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute, No. 10 West Kaifa Road, Yangzhou, 225009 Jiangsu, P. R. China.
Construction:	Framed, with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500V DC
Fire Safety Class:	Class C according to UL790

Tested according to:

IEC 61215-1:2016
 IEC 61215-1-1:2016
 IEC 61215-2:2016
 IEC 61730-1:2016
 IEC 61730-2:2016
 EN 61215-1:2016
 EN 61215-1-1:2016
 EN 61215-2:2017
 EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06